

Client/Code

Cobble Hill Improve. District
*A
P.O. Box 27
Cobble Hill, BC
V0R 1L0

Date 23Jul20 3:40p No. W155342
Source FWS
Type of Sample water
No. of Samples 3

TEL: (250) 743-2861
1979chid@gmail.com

Comments Arrival temp.: 18.2C
Sampler: Alan Seal

Site Code	Date	Time	CFU/100 ml		CFU/100 ml		CFU/100 mL
			TC	T-NC	FC	F-NC	E.coli
1 Cenetaph Park	23Jul20	11:11a	0	0	0	0	0
2 Garland & Fisher	23Jul20	11:10a	0	0	0	0	0
3 Hutchinson West	23Jul20	11:17a	0	0	0	0	0

TC = total coliform bacteria
FC = fecal coliform bacteria (aka thermotolerant coliforms)
NC = non-coliform bacteria
CFU/100 ml = colony forming units per 100 milli-litres

Results may be adversely affected if samples are submitted to the laboratory more than 24 to 30 hours after collection.

E. coli = Escherichia coli, FDA/BAM 8th ed, 1995 + Revision A, 1998
Bergy's Manual of Systematic Bacteriology vol 1, AOAC 1984; J.Clin.Micro.,
J.Intern.System.Bact.



W. Riggs
Sr. Microbiologist

