

Client/Code

Cobble Hill Improve. District
 *A
 P.O. Box 27
 Cobble Hill, BC
 VOR 1L0

Date 01Jun21 4:14p No. W161636
 Source Well
 Type of Sample water
 No. of Samples 2

TEL: (250) 743-2861
 group


Comments Arrival temp.: 14.0C
 Sampler: Alan Seal

SAMPLE	DATE	TIME	NH ₃ -N (ug/L)	E.C. (uS/cm)	TKN (mg/L)	NO ₃ -N (mg/L)	NO ₂ -N (ug/L)
1 Fisher Rd Well	01Jun21	09:25a	ND	0.320	0.670	2.22	ND
2 Holland Rd Well	01Jun21	09:35a	ND	0.310	0.443	2.89	ND
Lab Blank			ND	ND	ND	ND	ND
S ₀			0.254	0.300	0.012	0.160 ug/L	0.300
REF. VALUE			20.0	147	1.00	1.00	10.0
STD ± 2SD			20.0 ± 1.38	147 ± 7.36	1.07 ± 0.072	1.00 ± 0.057	9.95 ± 0.645

SAMPLE	DATE	TIME	TN (mg/L)	ORG.N (mg/L)	Turbidity (NTU)
1 Fisher Rd Well	01Jun21	09:25a	2.89	0.670	0.400
2 Holland Rd Well	01Jun21	09:35a	3.33	0.443	0.240
Lab Blank			ND	ND	ND
S ₀			0.030	0.012	0.015
REF. VALUE			1.00	1.00	5.00
STD ± 2SD			1.07 ± 0.080	0.980 ± 0.011	5.01 ± 0.300

SD = standard deviation; REF VALUE = primary or secondary reference material
 STD = secondary standard calibrated to primary standard reference material
 S₀ = standard deviation at zero analyte concentration; method detection limit
 is generally considered to be 3x S₀ value
 ND = none detected n/a = not applicable

 R. Bilodeau
 Analytical Chemist



 H. Hartmann
 Sr. Analytical Chemist

