

Client/Code

Cobble Hill Improve. District
*A
P.O. Box 27
Cobble Hill, BC
VOR 1L0

Date 23Feb21 3:03p No. W159459
Source FWS
Type of Sample water
No. of Samples 1

TEL: (250) 743-2861
1979chid@gmail.com

Comments Arrival temp.: 8.6C
Sampler: Alan Seal

Site Code	Date	Time	CFU/100 ml		CFU/100 ml		CFU/100 ml
			TC	T-NC	FC	F-NC	E.coli
Fisher Rd Well Head	23Feb21	09:40a	0	0	0	0	0

WATER DISTRICT SCREEN

Sample	Date	Time	Lactose	Coliforms		Total	Sulfur Reducing/		TPC*	
			Fermentors	Total	Fecal	E.coli	Aeromonas	Iron Bacteria		Yeast/Fungi
Fisher Rd Well Head	23Feb21	09:40a	ND	ND	ND	ND	ND	ND / ND	ND / ND	0.18


* all counts are colony forming units per milli-litre

TC = total coliform bacteria FC = fecal coliform bacteria (aka Thermotolerant Coliforms)
NC = non-coliform bacteria ND = none detected
TPC = total plate count- spread plate method - 35C/48hr TGEA FDA/BAM 9th ed, Oct 2020
CFU = colony forming units

Results may be adversely affected if samples are submitted to the laboratory more than 24 to 30 hours after collection.

E. coli = Escherichia coli, FDA/BAM 9th ed, Oct 2020
Bergey's Manual of Systematic Bacteriology vol 1, AOAC 1984; J.Clin.Micro., J.Intern.Systm.Bact.

- see following page for chemistry results -


W. Riggs
Sr. Microbiologist



Client/Code

Cobble Hill Improve. District
 *A
 P.O. Box 27
 Cobble Hill, BC
 V0R 1L0

Date 23Feb21 3:03p
 Source FWS
 Type of Sample water
 No. of Samples 1

No. W159459 pg2

TEL: (250) 743-2861
 1979chid@gmail.com

Comments Arrival temp.: 8.6C
 Sampler: Alan Seal

Sample: Fisher Rd Well Head 23Feb21 09:40a

				Maximum Limits Permissible
				In Drinking Water*
ELEMENTS		SAMPLE	UNITS	
1) Aluminium	Al	0.099	mg/L	no limit listed
2) Antimony	Sb	<0.500	ug/L	6.00 ug/L
3) Arsenic	As	<0.500	ug/L	10.0 ug/L
4) Barium	Ba	<0.009	mg/L	1.00 mg/L
5) Beryllium	Be	<0.003	mg/L	no limit listed
6) Bismuth	Bi	<0.100	ug/L	no limit listed
7) Boron	B	0.428	mg/L	5.00 mg/L
8) Cadmium	Cd	0.113	ug/L	5.00 ug/L
9) Calcium	Ca	19.2	mg/L	200 mg/L
10) Chromium	Cr	<0.010	mg/L	0.050 mg/L
11) Cobalt	Co	<0.020	mg/L	no limit listed
12) Copper	Cu	<0.008	mg/L	1.00 mg/L
13) Gold	Au	<0.040	mg/L	no limit listed
14) Iron	Fe	0.013	mg/L	0.300 mg/L
15) Lanthanum	La	<0.020	mg/L	no limit listed
16) Lead	Pb	<0.500	ug/L	5.00 ug/L
17) Lithium	Li	<0.100	ug/L	no limit listed
18) Magnesium	Mg	8.29	mg/L	50.0 mg/L
19) Manganese	Mn	<0.004	mg/L	0.120 MAC 0.020 AO
20) Mercury	Hg	0.098	ug/L	1.00 ug/L
21) Molybdenum	Mo	<0.020	mg/L	no limit listed
22) Nickel	Ni	<0.050	mg/L	no limit listed
23) Phosphorus	P	0.038	mg/L	no limit listed
24) Potassium	K	0.510	mg/L	no limit listed
25) Scandium	Sc	<0.050	mg/L	no limit listed
26) Selenium	Se	<0.500	ug/L	5.0 ug/L
27) Silicon	Si	7.11	mg/L	no limit listed
28) Silver	Ag	<0.010	mg/L	no limit listed
29) Sodium	Na	4.94	mg/L	200 mg/L
30) Strontium	Sr	0.070	mg/L	no limit listed
31) Tellurium	Te	<0.100	ug/L	no limit listed
32) Thallium	Tl	<0.100	ug/L	no limit listed
33) Thorium	Th	<0.100	ug/L	no limit listed
34) Tin	Sn	<0.020	mg/L	no limit listed
35) Titanium	Ti	<0.010	mg/L	no limit listed
36) Tungsten	W	<0.050	mg/L	no limit listed
37) Uranium	U	<0.100	ug/L	no limit listed
38) Vanadium	V	<0.010	mg/L	no limit listed
39) Zinc	Zn	0.026	mg/L	5.00 mg/L
40) Zirconium	Zr	<0.100	ug/L	no limit listed
Hardness (mg/L CaCO ₃)		82.1	mg/L	75-150 mg/L = mod.hard
pH		7.56	units	7.0 to 10.5

* As per Canadian or B.C. Health Act Safe Drinking Water Regulation BC Reg 230/92, & 390 Sch 120, 2001. Task Force of Canadian Council of Resource & Envir. Ministers Guidelines for Canadian Drinking Water Quality, 2019.



ANALYTICAL & TESTING SERVICES

R. Bilodeau
 Analytical Chemist

P.O. BOX 2103, SIDNEY, B.C. V8L 3S6

H. Hartmann
 Sr. Analytical Chemist

TEL: (250) 656-1334 EMAIL: info@mblabs.com

Client/Code

Cobble Hill Improve. District
 *A
 P.O. Box 27
 Cobble Hill, BC
 V0R 1L0

Date 23Feb21 3:03p No. W159459 pg3
 Source FWS
 Type of Sample water
 No. of Samples 1

TEL: (250) 743-2861
 1979chid@gmail.com

Comments Arrival temp.: 8.6C
 Sampler: Alan Seal

SAMPLE	DATE	TIME	Alkalinity (mg/L)	NH ₄ (ug/L)	TKN (mg/L)	TN (mg/L)
Fisher Rd Well Head Lab Blank	23Feb21	09:40a	90.0 ND	3.50 ND	0.252 ND	2.91 ND
So			0.100	0.254	0.012	0.030
REF. VALUE			200	10.0	1.00	10.0
STD ± 2SD			190 ± 17.8	10.4 ± 0.88	0.980 ± 0.079	10.6 ± 0.722

SAMPLE	DATE	TIME	D.Cl ⁻ (mg/L)	Colour (TCU)	E.C. (uS/cm)	Corrosivity (Is @20)
Fisher Rd Well Head Lab Blank	23Feb21	09:40a	10.9 ND	1.15 ND	195 ND	-0.590
So			0.015	0.300	0.300	
REF. VALUE			10.0	5.00	147	
STD ± 2SD			10.3 ± 0.766	4.92 ± 0.422	142 ± 13.2	

SAMPLE	DATE	TIME	D.F ⁻ (mg/L)	NO ₃ -N (mg/L)	NO ₂ -N (ug/L)
Fisher Rd Well Head Lab Blank	23Feb21	09:40a	0.0389 ND	2.66 ND	ND ND
So			0.007	0.160 ug/L	0.300
REF. VALUE			1.00	10.0	10.0
STD ± 2SD			1.04 ± 0.090	9.82 ± 0.776	10.4 ± 1.01

SAMPLE	DATE	TIME	TP0 ₄ ^{3--P} (ug/L)	D.S0 ₄ ²⁻ (ug/L)	H ₂ S (ug/L)
Fisher Rd Well Head Lab Blank	23Feb21	09:40a	12.0 ND	4.07 ND	ND ND
So					
REF. VALUE			10.0	10.0	50.0
STD ± 2SD			10.6 ± 0.822	10.4 ± 1.02	50.4 ± 4.88

...contin/



Client/Code

Cobble Hill Improve. District
*A
P.O. Box 27
Cobble Hill, BC
V0R 1L0

Date 23Feb21 3:03p No. W159459 pg4
Source FWS
Type of Sample water
No. of Samples 1


TEL: (250) 743-2861
1979chid@gmail.com

Comments Arrival temp.: 8.6C
Sampler: Alan Seal

<u>SAMPLE</u>	<u>DATE</u>	<u>TIME</u>	<u>D.O.C.</u> <u>(mg/L)</u>	<u>TDS</u> <u>(mg/L)</u>	<u>Turbidity</u> <u>(NTU)</u>
Fisher Rd Well Head	23Feb21	09:40a	2.83	113	0.200
Lab Blank			ND	ND	ND
S ₀			0.300	0.010	0.015
REF. VALUE			5.00	200	0.500
STD ± 2SD			5.08 ± 0.433	190 ± 17.0	0.490 ± 0.042

SD = standard deviation; REF VALUE = primary or secondary reference material
STD = secondary standard calibrated to primary standard reference material
S₀ = standard deviation at zero analyte concentration; method detection limit
is generally considered to be 3x S₀ value
ND = none detected n/a = not applicable

R. Bilodeau
Analytical Chemist



H. Hartmann
Sr. Analytical Chemist

