

Cobble Hill Improve. District
*A
P.O. Box 27
Cobble Hill, BC
V0R 1L0

TEL: (250) 701-5193
group

11Jun24 2:21p
Source: FWS
Type of Sample: water
No. of Samples: 2

W181044

Arrival temp.: 6.0C
Sampler: Alan Seal


Sample: Cobble Hill Imp Dist

<u>SAMPLE</u>	<u>DATE</u>	<u>TIME</u>	<u>NH₃-N (ug/L)</u>	<u>E.C. (uS/cm)</u>	<u>TKN (mg/L)</u>	<u>NO₂-N (ug/L)</u>	<u>NO₃-N (ug/L)</u>
Fisher Rd Well	11Jun24	09:15a	10.9	213	0.011	3.01	ND
Holland Road Well	11Jun24	09:27a	4.50	372	0.337	3.48	ND
Lab Blank			ND	ND	ND	ND	ND
So			0.254	0.300	0.012	0.160	0.300
REF. VALUE			10.0	147	1.00	10.0	10.0
STD ± 2SD			9.64 ± 7.12	141 ± 12.0	1.07 ± 0.074	9.82 ± 0.678	10.4 ± 0.802

<u>SAMPLE</u>	<u>DATE</u>	<u>TIME</u>	<u>TN (mg/L)</u>	<u>ORG.N (mg/L)</u>	<u>Turbidity (NTU)</u>
Fisher Rd Well	11Jun24	09:15a	3.02	ND	0.150
Holland Road Well	11Jun24	09:27a	3.82	0.332	0.450
Lab Blank			ND	ND	ND
So				0.012	0.01
REF. VALUE				1.00	10.0
STD ± 2SD				0.986 ± 0.064	9.81 ± 0.750

SD = standard deviation; REF VALUE = primary or secondary reference material
STD = secondary standard calibrated to primary standard reference material
So = standard deviation at zero analyte concentration; method detection limit
is generally considered to be 3x So value
ND = none detected n/a = not applicable

R. Bilodeau
Analytical Chemist



H. Hartmann
Sr. Analytical Chemist

M.B. LABS LTD
T: 250 656-1334

E: info@mblabs.com

W: www.mblabs.com

