

Client/Code

Cobble Hill Improve. District  
 \*A  
 P.O. Box 27  
 Cobble Hill, BC  
 V0R 1L0

TEL: (250) 743-2861  
 group


Date 14Jun22 3:16p No. W168636  
 Source Well  
 Type of Sample water  
 No. of Samples 2  
 Comments Arrival temp.: 9.6C  
 Sampler: Alan Seal

SAMPLE	DATE	TIME	NH <sub>3</sub> -N (ug/L)	E.C. (uS/cm)	TKN (mg/L)	NO <sub>3</sub> -N (mg/L)	NO <sub>2</sub> -N (ug/L)
1 Fisher Road Well	14Jun22	09:16a	ND	207	0.601	2.22	ND
2 Holland Road Well	14Jun22	09:07a	ND	375	0.777	2.51	ND
Lab Blank			ND	ND	ND	ND	ND
S <sub>o</sub>			0.254	0.300	0.012	0.160 ug/L	0.300
REF. VALUE			10.0	147	1.00	10.0	10.0
STD ± 2SD			9.87 ± 0.890	142 ± 12.0	0.982 ± 0.0790	10.4 ± 1.01	9.87 ± 0.778

SAMPLE	DATE	TIME	TN (mg/L)	ORG.N (mg/L)	Turbidity (NTU)
1 Fisher Road Well	14Jun22	09:16a	2.82	0.601	0.210
2 Holland Road Well	14Jun22	09:07a	3.29	0.777	0.220
Lab Blank			ND	ND	ND
S <sub>o</sub>			0.030		0.015
REF. VALUE			10.0		0.500
STD ± 2SD			10.6 ± 0.889		0.530 ± 0.042

SD = standard deviation; REF VALUE = primary or secondary reference material  
 STD = secondary standard calibrated to primary standard reference material  
 S<sub>o</sub> = standard deviation at zero analyte concentration; method detection limit  
 is generally considered to be 3x S<sub>o</sub> value  
 ND = none detected n/a = not applicable

\_\_\_\_\_  
 R. Bilodeau  
 Analytical Chemist

  
 \_\_\_\_\_  
 H. Hartmann  
 Sr. Analytical Chemist

