

Cobble Hill Improve. District
 *A
 P.O. Box 27
 Cobble Hill, BC
 V0R 1L0

12Sep22 3:06p
 Well
 water
 2

W170223

TEL: (250) 701-5193
 group

Arrival temp.: 6.8C
 Sampler: Ailsa Lenk

SAMPLE	DATE	TIME	NH3-N (ug/L)	E.C. (uS/cm)	TKN (mg/L)	NO3-N (mg/L)	NO2-N (ug/L)
1 Fisher Road Well	12Sep22	09:50a	42.5	208	0.043	3.09	ND
2 Holland Road Well	12Sep22	10:00a	40.1	254	0.040	2.65	ND
Lab Blank			ND	ND	ND	ND	ND
So			0.254	0.300	0.012	0.160 ug/L	0.300
REF. VALUE			100	147	1.00	10.0	100
STD ± 2SD			94.4 ± 7.55	141 ± 13.1	0.988 ± 0.079	10.4 ± 0.787	98.0 ± 8.88

SAMPLE	DATE	TIME	TN (mg/L)	ORG.N (mg/L)	Turbidity (NTU)
1 Fisher Road Well	12Sep22	09:50a	3.13	ND	0.260
2 Holland Road Well	12Sep22	10:00a	2.69	ND	0.940
Lab Blank			ND		ND
So			0.030		0.015
REF. VALUE			1.00		0.500
STD ± 2SD			1.08 ± 0.090		0.530 ± 0.048

SD = standard deviation; REF VALUE = primary or secondary reference material
 STD = secondary standard calibrated to primary standard reference material
 So = standard deviation at zero analyte concentration; method detection limit
 is generally considered to be 3x So value
 ND = none detected n/a = not applicable

 R. Bilodeau
 Analytical Chemist

 H. Hartmann
 Sr. Analytical Chemist

M.B. LABS LTD
 T: 250 656-1334

E: info@mblabs.com

W: www.mblabs.com